



INDIANA
DEPARTMENT
OF LABOR

2015 Mock IOSHA Inspection

Presented by
IOSHA Construction Safety



INDIANA
DEPARTMENT
OF LABOR

IOSHA Presenters

Tim Maley – Deputy Commissioner IOSHA
Jerry Lander – Director Construction Safety
Kevin Goeden – Training Officer / Abatement
Ellen Osborne – Senior Compliance Officer
Josh Schermerhorn – Compliance Officer
John Grimes – Supervisor Construction Safety

Why is IOSHA at my site?



INDIANA DEPARTMENT OF LABOR



Types of Inspections

1. Accident Inspection
2. Fatality / Catastrophe Inspection
3. Complaint Inspection
4. Referral Inspection
5. Follow up Inspection
6. General Schedule Inspection

INDIANA DEPARTMENT OF LABOR



General Schedule Inspection Management assigns permit to the compliance officer



INDIANA DEPARTMENT OF LABOR



What happens next when OSHA shows up at your site?



INDIANA DEPARTMENT OF LABOR



Opening Conference



INDIANA DEPARTMENT OF LABOR



What will you be asked for at the opening conference?

1. You will be informed why OSHA is on your project.
2. Copy of your Health and Safety Program.
3. 300 & 300a Logs for the last three years.
4. You will be asked general information questions and we will ask you to fill out some company information forms.

INDIANA DEPARTMENT OF LABOR



Now the inspection begins



INDIANA DEPARTMENT OF LABOR



Four Elements of a Violation

1. Standard applies
2. Standard violated
3. Employee exposure
4. Employer knowledge

INDIANA DEPARTMENT OF LABOR



Alleged Violations # 1, 2, & 3



INDIANA DEPARTMENT OF LABOR



Lanyard connected back to its self and rip pack not connected to employees back D ring



INDIANA DEPARTMENT OF LABOR



Missing Guard and no PPE



INDIANA DEPARTMENT OF LABOR



Guard Wedged Open



INDIANA DEPARTMENT OF LABOR



Wheel Not in Locked Position



INDIANA DEPARTMENT OF LABOR



Strain Relief



INDIANA DEPARTMENT OF LABOR



Missing Cover Plate Missing Set Screw Connector



INDIANA DEPARTMENT OF LABOR



INDIANA DEPARTMENT OF LABOR



Knockout removed, not covered, not labeled correctly, and damaged breaker



INDIANA DEPARTMENT OF LABOR



INDIANA DEPARTMENT OF LABOR



Missing cover plate
Exposed to live parts
Romex wire
Not used as labeled and or
listed



INDIANA DEPARTMENT OF LABOR



Temporary Power Taps
Prohibited
No Daisy Chaining



INDIANA DEPARTMENT OF LABOR



Ladder not folded out and locks not deployed or PPE



INDIANA DEPARTMENT OF LABOR



Unprotected Rebar



INDIANA DEPARTMENT OF LABOR



Employee Interviews



INDIANA DEPARTMENT OF LABOR



Closing Conference



INDIANA DEPARTMENT OF LABOR



Compliance Officer completes the file



INDIANA DEPARTMENT OF LABOR



Supervisor receives the file and reviews it and gives it to the director for safety orders



INDIANA DEPARTMENT OF LABOR



Four Elements of a violation

1. Standard applies
2. Standard violated
3. Employee exposure
4. Employer knowledge

INDIANA DEPARTMENT OF LABOR



Safety orders are received by the contractor by certified mail



INDIANA DEPARTMENT OF LABOR



Informal Conference In person or by phone



INDIANA DEPARTMENT OF LABOR



INDIANA DEPARTMENT OF LABOR

- Hazards that were cited:
 - Competent person
 - Safety training
 - No safety glasses
 - Guard on chop saw circumvented
 - No guard on grinder
 - Open spot on electrical panel
 - Conduit going into outlet on pole not attached leaving a gap
 - No strain relief yellow cord female end
 - No outlet cover x 2
 - Ladder not used for its intended purpose
 - Lanyard hooked incorrectly
 - Ladder training



INDIANA DEPARTMENT OF LABOR

- Hazards that were not cited:
- Wheels not locked on scaffolding
- Bucket used to get on mobile scaffolding
- Damaged end on breaker
- Power strips x 2
- Rebar not capped

Contest Safety Orders Board of Safety Review



INDIANA DEPARTMENT OF LABOR



INSafe Consultation

- Free, confidential and onsite
 - Workplace safety and health consultation
 - Safety audit
 - Health audit/industrial hygiene sampling
 - Training



INDIANA DEPARTMENT OF LABOR



INDIANA DEPARTMENT OF LABOR





INDIANA
DEPARTMENT
OF LABOR

Questions